



NOTES:

1. COUPLING SHALL BE "BAND-SEAL" ADJUSTABLE COMPRESSION COUPLING FOR SEWER REPAIR OR APPROVED EQUAL.
2. CENTER COUPLING OVER ONE JOINT AT A TIME AND TIGHTEN OUTER BOLTS.
3. AFTER OUTER BOLTS ON BOTH COUPLINGS ARE TIGHTENED, THEN TIGHTEN SHEAR RING.
4. ALL CLAMPS, SHEAR RINGS, AND HARDWARE SHALL BE TYPE 316 STAINLESS STEEL.



**FAIRFIELD-SUISUN  
SEWER DISTRICT**

1010 CHADBOURNE RD.  
FAIRFIELD, CA 94534-9700  
(707) 429-8930 PH  
(707) 429-1280 FX

**PUMP STATION AND COLLECTION SYSTEM DESIGN STANDARDS**

**VCP REPAIR COUPLING DETAIL**

NOT TO SCALE

DETAIL NO.

**5**

DATE  
9/21